



ARIZONA FIRE MARSHAL'S ASSOCIATION

MOBILE FOOD UNIT INSPECTION

Business Name: _____ Date: _____
 Address: _____ Phone: _____
 City: _____ Zip Code: _____
 Email Address: _____
 MFU License Plate #: _____ AHJ: _____

GENERAL OFF-SITE		YES	NO	N/A
1.	Portable fire extinguisher(s) 2A:20BC are installed in kitchen cooking areas. [2018 NFPA 96:10.9.3]			
2.	Cooking appliances that produce grease-laden vapors protected by listed fire extinguisher [Class K]. [2018 NFPA 96:14.7.1]			
3.	Flexible connector is installed between the regulator outlet and the fixed piping system. [2017 NFPA 58:6.26.5.1(B)]			
4.	Cooking equipment that produces grease-laden vapor shall be provided with kitchen exhaust hood in accordance with 2018 IFC Section 607 [2018 IFC 319.3].			
5.	The exhaust system including, hood, grease-removal devices, fans, ducts and other appurtenances, shall be inspected and cleaned in accordance with 2018 IFC Section 607.3 [2018 IFC 319.10.1].			
6.	Cooking equipment shall be protected by automatic fire extinguishing system in accordance with 2018 IFC Section 904.12 [2018 IFC 319.4.1].			
7.	Fire protection system and devices shall be maintained in accordance with 2018 IFC Section 906.1 [2018 IFC 319.10.2].			
8.	LP gas containers installed on the vehicle shall be securely mounted and restrained to prevent movement. [2018 IFC 319.8.2]			
9.	LP gas system piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage, and damage from vibration [2018 IFC 319]			
10.	Maximum aggregate capacity of LP gas containers transported on the vehicle and used to fuel cooking appliances only shall not exceed 200 pounds propane capacity. [2018 IFC 319.8.1]			
11.	A listed LP gas alarm shall be installed within the vehicle in the vicinity of LP gas system components , in accordance with the manufacturer's instruction. [2018 IFC 319.8.5]			
12.	LP gas containers installed on the vehicle and fuel gas piping system shall be inspected annually by an approved inspection agency or a company that is registered with the US Department of Transportation to re-qualify LP gas cylinders, to ensure that system components are free from damage, suitable for the intended service and not subject to leaking.			

SOLID FUEL OPERATIONS:		YES	NO	N/A
1.	Solid fuel is not stored above any heat-producing appliance or vent. [2018 NFPA 96:14.9.2.2]			
2.	Solid fuel is not stored closer than 3 ft from any cooking appliance. [2018 NFPA 96:14.9.2.2]			
3.	Solid fuel is not stored near any combustible flammable liquids, ignition sources, chemicals. [2018 NFPA 96:14.9.2.7]			
4.	Solid fuel is not stored in the path of the ash removal or near removed ashes. [2018 NFPA 96:14.9.2.4]			
5.	Ash, cinders and other fire debris should be removed from the firebox at regular intervals and at least once a day. [2018 NFPA 96:14.9.3.6.1]			
6.	Removed ashes, cinders and other removed debris should be placed in a closed, metal container located at least 3 feet from any cooking appliance. [2018 NFPA 96:14.9.3.8]			

Mobile Food Vendor Operator Signature: _____ Date: _____
 Inspector Name: _____ Title/Rank: _____
 Inspector Signature: _____ Date: _____

This is a consensus document presented by the Arizona Fire Marshal's Association in partnership with the membership.

